



NET4GAS, s.r.o

LINE VALVE STATION MLADOTICE MODIFICATION

Noise Study

03.12.2018

ILF CONSULTING ENGINEERS

Werner-Eckert-Strasse 7, 81829 München, DE
Jirsíkova 5, 186 00 Praha 8, CZ

Phone: +49 89 25 55 94-0
+420 255 091 420

E-mail: info.muc@ilf.com
info.prg@ilf.com

Website: www.ilf.com



REVISION HISTORY

002	03.12.2018	Approved	Eckbauer	Foltin	Schorling
001	19.11.2018	Approved	Eckbauer	Foltin	Schorling
000	29.10.2018	Approved	Eckbauer	Foltin	Schorling
B01	04.09.2018	Issue for Review	Juriscic / Trummer	Eckbauer	Schorling
A01	28.08.2018	Issue for IDC	Juriscic	Trummer	Eckbauer
Rev.	Date	Issue, Purpose	Prepared	Checked	Approved

TABLE OF CONTENTS

1	GENERAL	4
	1.1 Scope of the Document	4
	1.2 Definitions	4
	1.3 Abbreviations	4
	1.4 References	5
	1.5 Codes and Standards	5
2	CALCULATION METHODE AND SOFTWARE	6
3	INPUT DATA	7
	3.1 Applicable Noise Limits	7
	3.2 Noise Emission Data	7
	3.3 Approach of the study	10
	3.4 Plant Layout	11
	3.5 IMMI Model	12
	3.6 Immission Points	14
4	RESULTS	15
5	CONCLUSION	17
6	ATTACHMENT	18

1 GENERAL

1.1 Scope of the Document

The aim of this noise study is to investigate the noise emissions of the modification of the LVS Mladotice. The study will support the decision making process for noise protection measure of the Stations.

1.2 Definitions

Term	Explanation
Project	Modification of LVS Mladotice
Employer	NET4GAS
Consultant	ILF Consulting Engineers

1.3 Abbreviations

Term	Explanation
LVS	Line Valve Station
dB	decibel
dB(A)	A-weighted decibel
FCV	Flow control valve

1.4 References

No.	Number	Title
1	C4G-MLAD-CHE-TU40S-STR-PID-101-DVZ	Piping & Instrumentation Diagram
2	C4G-MLAD-CHE-TU40S-STR-PFD-090-DVZ	Process Flow Diagram
3	C4G-MLAD-CHE-TU40S-GEN-SIT-014-DVZ	C.3-Coordination Layout Plan

1.5 Codes and Standards

No.	Number	Title
1	ISO 9613	Acoustics -- Attenuation of sound during propagation outdoors
2	VDI 3760	Berechnung und Messung der Schallausbreitung in Arbeitsräumen
3	VDI 3733	Geräusche bei Rohrleitungen
4	272/2011	GOVERNMENT REGULATION of 24 August 2011 on the protection of health from the adverse effects of noise and vibrations
5	TA Lärm	Technische Anleitung zum Schutz gegen Lärm

2 CALCULATION METHODE AND SOFTWARE

The calculations are based on ISO 9613 to determine resultant environmental noise levels from source sound power levels.

The propagation of noise is calculated by using the software "IMMI 2017", released by the company "Wölfel Measuring Systems". The software takes into account physical influences such as reflection on barriers and their screening effect.

The local meteorological influence C0 was set to 0 dB. The sound absorption in air was calculated by taking into account an ambient temperature of 10 °C and a relative humidity of 70 %.

Damping properties of soil components have been adopted for the surrounding countryside with a conservative value of 0.5 (slightly acoustically porous soil, arable land, meadows).

A noise map was generated based on a raster mesh size of 3 m x 3 m at a height of 4 m above ground level.

Reflections on walls and surfaces of 1st order with a reflection coefficient of 0.8 are taken into account.

3 INPUT DATA

3.1 Applicable Noise Limits

The acceptable sound pressure levels outside at residential areas in Czech Republic according to GOVERNMENT REGULATION of 24 August 2011 on the protection of health from the adverse effects of noise and vibrations are:

- Noise Levels at fence: 85 dB(A)
- Noise Levels at nearest neighbour:
 - Day time* 50 dB(A)
 - Night-time* 40 dB(A)

* Day is defined as the 16 hours between 06:00 to 22:00. Night is defined as the 8 hours between 22:00 and 06:00.

For comparison, 0 dB is the threshold of hearing, 140 dB is the threshold of pain. A change of 1 dB is detectable only under laboratory conditions. A change of 10 dB corresponds approximately to halving or doubling the human sensed loudness of sound.

3.2 Noise Emission Data

The only noise source at the LVS Mladotice is the flow control valve (FCV 60.1) installed above ground. The noise generated by the control valve and emitted by the upstream and downstream piping is also considered.

The emitted noise of the flow control valve is depending on the differential pressure and the flow rate. Four (4) flow cases are defined in the control valve datasheet (see Attachment 2). The cases have been assessed regarding noise at the control valve and the piping.

Based on vendor data for low noise trim valves (see Attachment 2) Case 2 and 3 are not considered, because they have a lower sound emission level than Case 1 and 4. Hence, Case 1 is defined as the worst case sound emission scenario, because according to VDI 3733 (equation 5) the higher flow in Case 1 compared to Case 4 causes higher sound emissions in the piping.

Consequently, the scenario with the highest noise emission is Case 1, which has the highest pressure drop, and the highest flow rate. Only Case 1 is considered in the following.

The emission data of the flow control valve with low noise trim (see Attachment 2) are based on vendor data. In order to get a more detailed analysis, the sound power level of the valve is considered within an octave spectrum from 63 to 8000 Hz.

Table 1 Sound power level of FCV 60.1 at LVS Mladotice

	Unit	Frequency spectrum								Sum
	Hz	63	125	250	500	1000	2000	4000	8000	
FCV 60.1	dB(A)	53,5	69,6	83,1	94,5	99,7	98,9	92,7	84,6	103,5

The sound sources are modelled as point sources in the software IMMI.

Furthermore, it is considered that the sound power which is emitted from FCV 60.1 to the environment, is also induced to the inside of the pipes. Therefore the sound power level emitted by the above-ground pipes (see Figure 1) is taken into regard for the modelling in IMMI. The data from the Piping Class CS-100-0 (see Attachment 4) is being used for this calculation in accordance with the procedure given by VDI 3733. Further noise insulation up- or downstream of the control valve is not considered.

For the four pipe segments the frequency spectrums of the sound power level are shown in Table 3.




Figure 1 Piping sections in Mladotice

The values for the flow and pressure (according to C4G-MLAD-CHE-TU40S-STR-PFD-090-DVZ) used in the simulation are summarized in Table 2 and represent the scenario with the highest noise emissions at LVS Mladotice (Case 1).

Table 2 Maximum pressure and flow for each piping section

Piping Section	Max. pressure [bar_g]	Max. flow [mmc/d 20°C]
1	58,5	26,5
2	85	26,5
3	85	26,5
4	85	26,5

Table 3 Total Sound power level of piping segments at LVS Mladotice

Piping Section	Unit	Frequency spectrum								
	Hz	63	125	250	500	1000	2000	4000	8000	Sum
1	dB(A)	15,4	36,0	55,0	72,3	83,5	88,6	77,5	60,4	90,1
2	dB(A)	9,6	33,8	52,3	69,5	80,6	85,3	74,5	57,5	86,9
3	dB(A)	14,4	36,7	54,8	71,5	81,9	85,9	75,3	58,4	87,7
4	dB(A)	11,3	33,6	51,7	68,3	78,9	82,9	72,2	55,3	84,8

This noise emission data for the piping is implemented as a line source in the model (ISO 9613-2).

It has to be assured that the various sound emitters shall not show tonal components.

No upset cases are considered which would lead to additional emission sources like running of diesel generator, as these are expected to occur only in emergency and not during normal operation.

No difference in day and night time noise emission is expected, which is why only the night time (stricter noise immission levels) is considered in the following.

There are only minor roads in the area. These are small and do not regularly serve heavy traffic. There are no official statistics available to calculate the road noise. This is why the background noise is not determined in the study but covered by the safety margin.

3.3 Approach of the study

The expected noise at the immission points at worst case conditions is calculated based on the sources in chapter 3.2. As the existing and background noise could not be quantified, a safety margin of 6 dB(A) (TA Lärm) should be deducted from the limits stated in chapter 3.1, which means that 34 dB(A) at the immission points would be acceptable.

If the immission limits are exceeded, measures to reduce noise emissions have to be taken. In this case, measures are proposed and the necessary reduction will be quantified.

For the calculation, the elevation profile is considered (source: <https://opentopomap.org>)

An overview of the LVS Mladotice is given in Figure 2 and the exact location of the one flow control valve (FCV 60.1) in Figure 3.




Figure 2 LVS Mladotice Layout




Figure 3 Location of FCV 60.1 in LVS Mladotice

3.5 IMMI Model

The following screenshots show the IMMI model. It contains the topography and existing buildings. The nearest neighbouring buildings are modelled with an assumed building height of 4 m. The heights of the buildings, which belong to the LVS are:

- Building 1 4,3 m
- Building 2 3 m
- Building 3 5 m
- Building 4 2,7 m

The colourations of the elements are depending on their function:

- Red areas: Noise emission sources
- Blue areas: Buildings
- Gray lines: Contour lines




Figure 4 IMMI model overview




Figure 5 IMMI model of LVS Mladotice

The IMMI input data is listed in Attachment 1.

3.6 Immission Points

The location of the nearest neighbours has been identified via aerial image and immission points have been placed at 4 m height at 0.5 m in front of the building facade. The following figures show the placement of the emission points:




Figure 6 Immission points at LVS Mladotice

The distances from the LVS Mladotice noise sources to the immission points are approximately

- | | |
|--------|-------|
| • IP_1 | 280 m |
| • IP_2 | 530 m |
| • IP_3 | 660 m |
| • IP_4 | 710 m |

4 RESULTS

The calculated sound pressure levels at the immission points are given in the following table. The emission level map is shown in Figure 7.

Table 4 Calculated sound pressure level at the immission points

Immission Point	Sound pressure level in dB(A)
IP_1	39.87
IP_2	19.71
IP_3	29.26
IP_4	23.12

The noise limit of 34 dB(A) is exceeded by 5.87 dB(A) at IP_1. The applicable noise limit at IP_2, IP_3 and IP_4 is kept.

If the preliminary vendor data is confirmed, noise reduction measures have to be taken to lower the sound pressure level at the immission points by 6 dB(A).




Figure 7: Noise map area

5 CONCLUSION

Please note that the calculations in this report are based on preliminary vendor data at worst case conditions. The considered valves use a low noise trim. If a different type of valve construction with even lower noise is available, this type could be used to lower noise emissions.

To safely comply within the applicable noise limits, a safety margin of 6 dB(A) was deducted from the applicable (272/2011) noise immission limits, as information on background and existing noise is available. Background noise measurements can be made to allow for calculation without safety margin. This results in a limit of 34 dB(A) at the relevant immission points.

This limit is exceeded by 6 dB(A), which means that noise reduction measures have to be applied at the flow control valves, if the vendor cannot reduce the noise at the valves itself.

If noise reduction at the FCVs is necessary, one or a combination of the following measures shall be used:

- Noise insulation directly applied on the valves (see Attachment 3).
- Noise insulation hoods around the valves (see Attachment 4 for requirements and typical),
- sound barriers or
- earth walls.
- Station piping upstream and downstream of the flow control valves to be equipped with noise insulation

The calculated necessary noise reduction of 6 dB(A), will be reviewed if new vendor data is available.

The noise estimation for such a control valve and adjacent piping are very hard to predict since the calculation is based on theoretical input data. Therefore, the EPC Contractor shall perform noise measurements after commissioning of each station to prove that the actual noise values are in line with the allowable limits. In case that the actual noise values exceed the allowable limits, the EPC Contractor is obliged to perform suitable noise protection measures to comply with the allowed limits. Such noise measures are part of EPC Contractor scope of work.

6 ATTACHMENT

Attachment 1 List of IMMI Input Data

Project Properties				
Topic:	Noise			
Type of prediction:	Noise (national methods)			
Rating following::	No rating	No.	Period	Duration/h
		1	Day	16.00
		2	Night	8.00
Project notes				

Work area				
	from ...	to ...	Dimensions	Area
x /m	-819990.00	-818780.00	1210.00	1.62 km²
y /m	-1044900.00	-1043560.00	1340.00	
z /m	-10.00	500.00	510.00	
Terrain height in the corners				
xmin / ymax (z4)	360.00	xmax / ymax (z3)	370.00	
xmin / ymin (z1)	360.00	xmax / ymin (z2)	380.00	

Available calculation areas												
Name	x min /m	x max /m	y min /m	y max /m	dx /m	dy /m	nx	ny	Reference	Height/m	Range	
Grid 0	-819990.00	-818780.00	-1044900.00	-1043560.00	20.00	20.00	61	68	relative	4.00	Work area	
Grid 1	-819990.00	-818780.00	-1044900.00	-1043560.00	3.00	3.00	404	447	relative	4.00	Work area	

Calculation parameters	Copy from "Reference Setting"	
Calculation model: General	Point calculation	Grid calculation
Adapt assessment area seamlessly to the receiver position		
L /m		
Terrain ridges as obstacles	Yes	Yes
Improved interpolation in boundary areas	Yes	Yes
Free field in front of refl. surfaces/m		
acc. to sources	1.0	1.0
acc. to immission points	1.0	1.0
House: white border in grid	No	No
Intermediate messages:	No	No
Calculation model: Parameters	"reference settings"	"reference settings"
Limiting range of sound sources:		
* Limit the search radius (distance source-IP):	No	No
* minimum level difference /dB:	No	No
Projection of line sound sources	Yes	Yes
Projection of area sound sources	Yes	Yes
Limit projection	No	No
* Radius /m around source:		
* Radius /m around IP:		
Minimum length for sections /m	1.0	1.0
Variable min. length for sections:		
* in percent of the distance from the IP source	No	No
Add. factor for distance criterion	1.0	1.0
Barrier attenuation differing from guideline:	No	No
* Cut-off limit for insertion loss:		
* Limit /dB for single screens:		
* Limit /dB for multiple screens:		
Calculate attenuation for VDI 2720, ISO9613		
* Lateral pathway	Yes	Yes
* Lateral pathway for image sources	No	No
Reflection		

Line Valve Station
Mladotice modification
Noise Study

C4G-HPPL-ILF-TU40S-BOZ-TZP-004-002

03.12.2018

Reflection (max. order)	1	1		
Limit the search radius (distance source-IP):	No	No		
* Search radius /m				
Limiting range of reflecting surfaces /m:				
* Radius around source or IP /m:	No	No		
* minimum level difference /dB:	No	No		
Image source from projection	Yes	Yes		
No refl. if entirely screened	Yes	Yes		
Save rays as help lines	No	No		
section control				
Section control acc. Schall 03 [2012]:	Yes	Yes		
Section control for other calculation methods, too:	No	No		
accelerated iteration (approximation):	No	No		
requested accuracy /dB:	0.1	0.1		
show intermediate results:	No	No		

Global parameters	Copy from "Reference Setting"					
Default for G outside DBOD-elements	0.50					
Temperature /°C	10					
Relative humidity /%	70					
Living area per inhab-/m² (=0.8*gross)	40.00					
Average storey height /m	2.80					
Simplified meteorology (Guideline Int. Comp. Methods):	Day	Evening	Night			
Simplified meteorology (Guideline Int. Comp. Methods):	0.00	0.00	0.00			

Parameters of library: ISO 9613-2	Copy from "Reference Setting"					
Downwind conditions	Yes					
Simplified equation (Nr. 7.3.2) for ground effect						
for frequency-dependent calculation	No					
for frequency-independent calculation	Yes					
Evaluating the mean height hm	according to ISO 9613-2 unmodified					
Simplified calculation using free propagation conditions (release zone excluded)	No					
Attenuation due to screening - subtract negative ground effect	No					
Deduction no more than to -Dz	No					
*Additional recommendations" - ISO TR 17534-3	Yes					
ABar acc. "Erlass Thüringen" (2015-01-10)	No					
Accounts for vegetation	Yes					
Accounts for housing	Yes					
Accounts for ground effect	Yes					

Contour line (15)					Variant 0
HOEL023	HoeL	Group 0	Length /m	602.39	
			Constant abs. height /m	405.00	
			Take into account as diffracting edge	Yes	
HOEL024	HoeL	Group 0	Length /m	739.52	
			Constant abs. height /m	403.00	
			Take into account as diffracting edge	Yes	
HOEL025	HoeL	Group 0	Length /m	1090.22	
			Constant abs. height /m	400.00	
			Take into account as diffracting edge	Yes	
HOEL026	HoeL	Group 0	Length /m	1478.09	
			Constant abs. height /m	395.00	
			Take into account as diffracting edge	Yes	
HOEL027	HoeL	Group 0	Length /m	1685.05	
			Constant abs. height /m	390.00	
			Take into account as diffracting edge	Yes	
HOEL028	HoeL	Group 0	Length /m	2096.24	
			Constant abs. height /m	385.00	
			Take into account as diffracting edge	Yes	
HOEL029	HoeL	Group 0	Length /m	2475.54	

Line Valve Station
Mladotice modification
Noise Study

C4G-HPPL-ILF-TU40S-BOZ-TZP-004-002

03.12.2018

			Constant abs. height /m	380.00	
			Take into account as diffracting edge	Yes	
HOEL030	HoeL	Group 0	Length /m	2772.36	
			Constant abs. height /m	375.00	
			Take into account as diffracting edge	Yes	
HOEL032	HoeL	Group 0	Length /m	3334.23	
			Constant abs. height /m	370.00	
			Take into account as diffracting edge	Yes	
HOEL033	HoeL	Group 0	Length /m	1046.56	
			Constant abs. height /m	365.00	
			Take into account as diffracting edge	Yes	
HOEL034	HoeL	Group 0	Length /m	921.40	
			Constant abs. height /m	360.00	
			Take into account as diffracting edge	Yes	
HOEL036	HoeL	Group 0	Length /m	1308.32	
			Constant abs. height /m	365.00	
			Take into account as diffracting edge	Yes	
HOEL037	HoeL	Group 0	Length /m	750.73	
			Constant abs. height /m	360.00	
			Take into account as diffracting edge	Yes	
HOEL038	HoeL	Group 0	Length /m	505.53	
			Constant abs. height /m	365.00	
			Take into account as diffracting edge	Yes	
HOEL039	HoeL	Group 0	Length /m	210.55	
			Constant abs. height /m	360.00	
			Take into account as diffracting edge	Yes	

Receiver point (16)							Variant 0	
	Label	Group	Limit /dB(A)	Use	T1	T2		
IPkt046	ImmissionPoint_3 1 H 1S/W	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt047	ImmissionPoint_3 2 H 1S/E	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt048	ImmissionPoint_3 3 H 1N/E	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt049	ImmissionPoint_3 4 H 1N/W	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt050	ImmissionPoint_1 1 H 1S/W	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt051	ImmissionPoint_1 2 H 1East	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt052	ImmissionPoint_1 3 H 1N/E	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt053	ImmissionPoint_1 4 H 1N/W	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt054	ImmissionPoint_2 1 H 1S/W	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt055	ImmissionPoint_2 2 H 1S/E	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt056	ImmissionPoint_2 3 H 1N/E	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt057	ImmissionPoint_2 4 H 1N/W	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt058	ImmissionPoint_4 1 H 1West	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt059	ImmissionPoint_4 2 H 1South	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt060	ImmissionPoint_4 3 H 1East	Group 0	Limit /dB(A)	---	-99.00	-99.00		
IPkt061	ImmissionPoint_4 4 H 1North	Group 0	Limit /dB(A)	---	-99.00	-99.00		

Line Valve Station
Mladotice modification
Noise Study

C4G-HPPL-ILF-TU40S-BOZ-TZP-004-002

03.12.2018

Building (8)					Variant 0
HAUS001	ImmissionPoint_4	Group 0	Reflection	--- No reflection	
			Building use	Resid. building	
			With special insulation	No	
			Residential use /%	100	
			No. of inhabitants	3.86	
			Number of dwellings	1.84	
			Number of storeys	1.43	
HAUS002	ImmissionPoint_3	Group 0	Reflection	--- No reflection	
			Building use	Resid. building	
			With special insulation	No	
			Residential use /%	100	
			No. of inhabitants	1.24	
			Number of dwellings	0.59	
			Number of storeys	1.43	
HAUS004	ImmissionPoint_1	Group 0	Reflection	--- No reflection	
			Building use	Resid. building	
			With special insulation	No	
			Residential use /%	100	
			No. of inhabitants	8.89	
			Number of dwellings	4.23	
			Number of storeys	1.43	
HAUS005	ImmissionPoint_2	Group 0	Reflection	--- No reflection	
			Building use	Resid. building	
			With special insulation	No	
			Residential use /%	100	
			No. of inhabitants	1.71	
			Number of dwellings	0.81	
			Number of storeys	1.43	
HAUS006	Bulding No. 2	Group 0	Reflection	--- No reflection	
			Building use	Resid. building	
			With special insulation	No	
			Residential use /%	100	
			No. of inhabitants	1.98	
			Number of dwellings	0.94	
			Number of storeys	1.07	
HAUS007	Haus	Group 0	Reflection	--- No reflection	
			Building use	Resid. building	
			With special insulation	No	
			Residential use /%	100	
			No. of inhabitants	1.06	
			Number of dwellings	0.50	
			Number of storeys	1.54	
HAUS008	Transformator	Group 0	Reflection	--- No reflection	
			Building use	Resid. building	
			With special insulation	No	
			Residential use /%	100	
			No. of inhabitants	9.95	
			Number of dwellings	4.74	
			Number of storeys	1.79	
HAUS009	Haus	Group 0	Reflection	--- No reflection	
			Building use	Resid. building	
			With special insulation	No	
			Residential use /%	100	
			No. of inhabitants	0.34	
			Number of dwellings	0.16	
			Number of storeys	0.96	

Vegetation (6)					Variant 0
DBwu001	DBwu	Group 0	D in dB/100m	5.00	
			transparent during winter (OE-Norm)	Yes	
			Pollutants (Gauss):	D in %/100m	10.00
DBwu002	DBwu	Group 0	D in dB/100m	5.00	

Line Valve Station
Mladotice modification
Noise Study

C4G-HPPL-ILF-TU40S-BOZ-TZP-004-002

03.12.2018

			transparent during winter (OE-Norm)	Yes	
			Pollutants (Gauss):	D in %/100m	10.00
DBwu004	DBwu	Group 0	D in dB/100m	5.00	
			transparent during winter (OE-Norm)	Yes	
			Pollutants (Gauss):	D in %/100m	10.00
DBwu005	DBwu	Group 0	D in dB/100m	5.00	
			transparent during winter (OE-Norm)	Yes	
			Pollutants (Gauss):	D in %/100m	10.00
DBwu006	DBwu	Group 0	D in dB/100m	5.00	
			transparent during winter (OE-Norm)	Yes	
			Pollutants (Gauss):	D in %/100m	10.00
DBwu007	DBwu	Group 0	D in dB/100m	5.00	
			transparent during winter (OE-Norm)	Yes	
			Pollutants (Gauss):	D in %/100m	10.00

Point source /ISO 96 (1)													Variant 0
EZQi001	Label	FCV 60.1		Action radius/m		99999.00							
	Group	Group 0		Lw (Day) /dB(A)		103.48							
	Number of nodes	1		Lw (Night) /dB(A)		103.48							
	Length/ m	---		D0		0.00							
	Length/ m (2D)	---		High building/high noise source		No							
	Area /m²	---		Emission is		Sound power level (Lw)							
	Emiss. variant		Sum	16 Hz	31.5 Hz	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz
	Day	Lw /dB (A)	103.5	0.0	0.0	53.5	69.6	83.1	94.5	99.7	98.9	92.7	84.6
	Night	Lw /dB (A)	103.5	0.0	0.0	53.5	69.6	83.1	94.5	99.7	98.9	92.7	84.6

Line source/ISO 9613 (5)													Variant 0
LIQi001	Label	Sound source		Action radius/m		99999.00							
	Group	Group 0		D0		0.00							
	Number of nodes	17		High building/high noise source		No							
	Length/ m	1660.53		Emission is		SPL per unit length (Lw/m)							
	Length/ m (2D)	1659.75		Emi. variant	Emission	Sound insul.	Correction	Lw	Lw'				
	Area /m²	---			dB(A)	dB	dB	dB(A)	dB(A)				
				Day	0.00	-	-	32.20	0.00				
				Night	0.00	-	-	32.20	0.00				
LIQi004	Label	Pipe 60.1_2		Action radius/m		99999.00							
	Group	Group 0		Lw (Day) /dB(A)		87.73							
	Number of nodes	2		Lw (Night) /dB(A)		87.73							
	Length/ m	17.97		Lw' (Day) /dB(A)		75.18							
	Length/ m (2D)	17.93		Lw' (Night) /dB(A)		75.18							
	Area /m²	---		D0		0.00							
				High building/high noise source		No							
				Emission is		Sound power level (Lw)							
	Emiss. variant		Sum	16 Hz	31.5 Hz	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz
	Day	Lw' /dB (A)	75.2	-12.5	-12.5	1.9	24.2	42.3	59.0	69.4	73.4	62.8	45.9
	Night	Lw' /dB (A)	75.2	-12.5	-12.5	1.9	24.2	42.3	59.0	69.4	73.4	62.8	45.9
LIQi008	Label	Pipe 60.1		Action radius/m		99999.00							
	Group	Group 0		Lw (Day) /dB(A)		90.10							
	Number of nodes	3		Lw (Night) /dB(A)		90.10							
	Length/ m	12.23		Lw' (Day) /dB(A)		79.22							
	Length/ m (2D)	12.19		Lw' (Night) /dB(A)		79.22							
	Area /m²	---		D0		0.00							
				High building/high noise source		No							
				Emission is		Sound power level (Lw)							
	Emiss. variant		Sum	16 Hz	31.5 Hz	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz
	Day	Lw' /dB (A)	79.2	-10.9	-10.9	4.5	25.1	44.1	61.4	72.6	77.7	66.6	49.5
	Night	Lw' /dB (A)	79.2	-10.9	-10.9	4.5	25.1	44.1	61.4	72.6	77.7	66.6	49.5
LIQi009	Label	Sound source		Action radius/m		99999.00							
	Group	Group 0		Lw (Day) /dB(A)		84.72							
	Number of nodes	3		Lw (Night) /dB(A)		84.09							
	Length/ m	19.48		Lw' (Day) /dB(A)		71.82							
	Length/ m (2D)	19.43		Lw' (Night) /dB(A)		71.20							
	Area /m²	---		D0		0.00							

Line Valve Station
Mladotice modification
Noise Study

C4G-HPPL-ILF-TU40S-BOZ-TZP-004-002

03.12.2018

			High building/high noise source								No			
			Emission is								Sound power level (Lw)			
	Emiss. variant		Sum	16 Hz	31.5 Hz	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	Day	Lw' /dB (A)	71.8	-12.9	-12.9	-1.6	20.7	38.8	55.4	66.0	70.0	59.3	42.4	
	Night	Lw' /dB (A)	71.2	-12.9	-12.9	-0.7	19.3	37.4	54.2	64.8	69.6	58.7	41.7	
LIQI011	Label	Sound source								Action radius/m				
	Group	Group 0								Lw (Day) /dB(A)				
	Number of nodes	2								Lw (Night) /dB(A)				
	Length/ m	11.00								Lw' (Day) /dB(A)				
	Length/ m (2D)	11.00								Lw' (Night) /dB(A)				
	Area /m ²	---								D0				
			High building/high noise source								No			
			Emission is								Sound power level (Lw)			
	Emiss. variant		Sum	16 Hz	31.5 Hz	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	Day	Lw' /dB (A)	76.5	-10.4	-10.4	-0.8	23.4	41.9	59.1	70.2	74.9	64.1	47.1	
	Night	Lw' /dB (A)	76.5	-10.4	-10.4	-0.8	23.4	41.9	59.1	70.2	74.9	64.1	47.1	

Line Valve Station
Mladotice modification
Noise Study

C4G-HPPL-ILF-TU40S-BOZ-TZP-004-002


03.12.2018


Attachment 2 Preliminary Vendor Data

NODE MLADOTICE MODIFICATION
PRESSURE CONTROL AND SAFETY SHUTOFF VALVES ≥ DN300


TU40_STR_SPC_506_03_DDL


CONTROL VALVE - DN 700 - DATASHEET							
GENERAL INFORMATION							
1	LOCATION		MLADOTICE - TU40		5	QUANTITY	
2	EQUIPMENT		PRESSURE / FLOW CONTROL VALVE		6	P&ID-No.	
3					7		
4	TAG No.		60.1		7	TECHNICAL SPECIFICATION	
5					8		
6	OPERATION AND DESIGN DATA						
9	AMBIENT CONDITIONS		TU40_STR_SPC_505_03_DDL		17	OUTLET SETTING PRESSURE	
10	FLUID		NATURAL GAS		18	ΔP @ FULL OPEN	
11	GAS COMPOSITION		TU40_STR_SPC_505_03_DDL		19	DESIGN PRESSURE	
12	PIPING CLASS		#600		20	DESIGN TEMPERATURE	
13	INSTALLATION		ABOVEGROUND		21		
14	DESIGN CODE / STANDARD		ČSN EN 1349		22		
15	MINIMUM SAFETY FACTOR		2,15		23		
16	FLANGE STANDARD / RATING		ASME B16.47 - RF / #600		24		
25	OPERATING / SERVICE CONDITIONS						
26			UNITS	CONDITION 1	CONDITION 2	CONDITION 3	CONDITION 4
27	FLOWRATE		Nm ³ /h	1 104 167	1 104 167	1 104 167	916 667
28	INLET PRESSURE P1		barg	85,0	85,0	58,5	85,0
29	OUTLET PRESSURE P2		barg	58,5	59,8		58,5
30	DIFFERENTIAL PRESSURE ΔP = P1 - P2		barg	26,5	25,2	-	26,5
31	INLET TEMPERATURE		°C	25	25	25	25,0
32	MOLAR WEIGHT		Kg/Kmol	16,3	16,3	16,3	16,3
33	VISCOSITY / SPECIFIC HEATS RATIO						
34	VAPOR PRESS. Pv / CRITICAL PRESS. Pc						
35	REQUIRED Cv			883	1126	6350	733
36	TRAVEL		%				
37	CALCULATED NOISE		dB(A)	86	81	<65	86
38	COMPRESSIBILITY (Z)			0.78	0.87	0.90	0.87
39	SOLIDS CONC. / PARTICLE SIZE						
40	VALVE DATA						
41	VALVE TYPE		RZD-REM1QX		51	SUPPORT LEGS	
42	VALVE BODY TYPE / DIMENSION		* PISTON		52	FLOW DIRECTION	
43	NOMINAL PIPE SIZE		DN 700		53	MAX. ALLOWABLE NOISE	
44	PIPELINE CONNECTION TYPE / SIZE		FLANGE / FLANGE		54	MAX. VALVE LIFT	
45	MAIN SEALS				55	STEM DIAMETER	
46	SECONDARY SEALS				56	ADJUSTABLE LIMIT STOP	
47	VALVE CHARACTERISTIC		EQUAL PERCENTAGE		57	LEAKAGE CLASS	
48	TRIM TYPE		AXIAL CONTROL VALVE		58		
49	SOUND ABSORPTION				59		
50	POSITION INDICATOR		YES		60		
61	ACTUATOR AND ACCESSORIES						
62	ACTUATOR TYPE		Pneum. - Nat. Gas (proc. med.)		73	POWER SUPPLY FOR SOLENOID VALVE	
63	MANUFACTURER / MODEL		N/A		74	EXP. PROOF-LIMIT SWITCHES	
64	AIR SUPPLY PRESSURE		85,0 barg (Natural Gas)		75	EXP. PROOF-HOUSING	
65	MIN. SUPPLY AIR PRESS. FOR OPERAT.		38,0 barg (Natural Gas)		76	STROKING TIME TO OPEN	
66	POSITIONER SIGNAL		4 - 20 mA		77	STROKING TIME TO CLOSE	
67	DESIGN TORQUE FOR ACTUATOR		YES, WITH LIMIT SWITCH		78	TEMPERATURE CLASS	
68	ELECTRICAL POWER SUPPLY		N/A		79	POSITIONER MANUFACT. / MODEL	
69	SIGNALLING AND CONTROL CONTACTS		4 - 20 mA		80	SOLENOID VALVE MANUFACT. / MODEL	
70	HAZARDOUS AREA		ZONE 2		81	HANDWHEEL	
71	IP-CODE		IP 65 (IEC 60529)		82	INSULATING CLASS	
72	AIR QUALITY		N/A (Natural Gas DVGW G260)		83	CORROSION PROTECTION	
84	DIMENSIONS, WEIGHT, MECHANICAL AND ELECTRICAL INTERFACES						
85	FITTING LENGTH		1549 F to F		89	WEIGHT (VALVE)	
86	FITTING HEIGHT				90	WEIGHT (VALVE + ACTUATOR)	
87	AIR SUPPLY CONNECTION		N/A		91	CABLE CONNECTION TYPE	
88					92	CABLE CONNECTION SIZE	
93	MATERIALS, TESTING AND DOCUMENTATION						
94	MATERIAL VALVE BODY		ASTM A351 Gr. LCC		103	TIGHTNESS TEST	
95	MATERIAL INTERNALS		CARBON STEEL		104	PRESSURE TESTING STANDARD	
96	MATERIAL END CONNECTIONS				105	SAFETY INTEGRITY LEVEL	
97	MATERIAL STEM		1.7218 - A322 G41300		106	FIRE SAFETY TESTING	
98	MATERIAL BOLTS / NUTS				107	ATEX CERTIFICATION	
99	MATERIAL SEAT / SEAL				108	TEST OF MATERIAL	
100	VALVE CORROSION PROTECTION		3 layer system total 240 μm		109	FINAL ACCEPTANCE TEST	
101			Top color RAL 1023		110	CE-CONFORMITY	
102					111		
112	NOTES						
113	◆ To be filled in/confirmed by Vendor						
114	This data sheet shall be read with document "TU40_STR_SPC_505_03_DDL Pressure Control and Safety Shutoff Valves ≥ DN 300 Specification"						
115	To be supplied with couterflanges, seals and joining material.						
116							
117							
118							
119							
120							
121							
122							
123							







TYPICAL DRAWING - IZOLAČNÍ ARMATURY POTRUBÍ - DN 700










Expected requirements for noise insulation hood (not concluding):

- Size to fit the valves (approx. 3 m x 3 m x 3 m)
- Noise reduction as specified
- Good accessibility (e.g. doors on both sides)
- Good ventilation to avoid ex zone or gas detectors if ex zone cannot be avoided
- Silencers for ventilation
- Inside lighting
- Foundation as plate or points (to be defined by static calculation)
- Steel frame to hold insulation plates



Line Valve Station

Mladotice modification

C4G-HPPL-ILF-TU40S-BOZ-TZP-004-002

Noise Study

03.12.2018

Attachment 5 Piping Class CS-100-0

		PIPING CLASS										Designation				CS100-0		
		Base Material	Carbon Steel				Service: Natural Gas Piping											
		Facing	RF	ASME CLASS		600		Color Coding										
		Corrosion Allow.	0 mm					Design Code				CSN EN 1594, TPG 702 04						
Design Conditions		Design Pressure (barg)	100															
		Design Temperature (°C)	-20 to +50						Pressure/ Temperature limits:				-20°C 100 barg	38°C 100 barg	50°C 100 barg			
Pipe Dimensions		Nominal Pipe Size [DN]	25	40	50	80	100	150	200	250	300	350	400	450	500	600	700	800
		Nominal Pipe Size [inch]	1	1½	2	3	4	6	8	10	12	14	16	18	20	24	28	32
		Outer Diameter [mm]	33.4	48.3	60.3	88.9	114.3	168.3	219.1	273.0	323.8	355.6	406.4	457.0	508.0	610.0	711.0	813.0
		Wall Thickness [mm]	4.00	4.00	4.00	4.00	4.50	7.10	8.80	11.00	8.80	10.00	11.00	12.50	12.50	16.00	17.50	17.50
		Nominal Pipe Size [DN]	900	1000	1100	1200	1400											
		Nominal Pipe Size [inch]	36	40	44	48	56											
		Outer Diameter [mm]	914.0	1016.0	1118.0	1219.0	1422.0											
		Wall Thickness [mm]	20.00	20.00	22.20	22.20	28.00											
Description		NPS		Code	Manufacturing/ Pressure Rating	Material & Standard				Design		NOTES						
		from	to															
Pipes	Pipe	1"	2"		seamless	L290NE		CSN EN ISO 3183		CSN EN ISO 3183								
		3"	10"		seamless	L290NE		CSN EN ISO 3183		CSN EN ISO 3183								
		12"	28"		long.welded	L360NE		CSN EN ISO 3183		CSN EN ISO 3183								
		32"	36"		long.welded	L415NE		CSN EN ISO 3183		CSN EN ISO 3183								
		40"	56"		long.welded	L485ME		CSN EN ISO 3183		CSN EN ISO 3183								
Flanges	Welding Neck Flanges	1"	10"		Forged / 600# RF	ASTM A350 LF2		ASTM A350		ASME B16.5								
		12"	24"		Forged / 600# RF	ASTM A350 LF2		ASTM A350		ASME B16.5								
		28"	36"		Forged / 600# RF	A694 Gr. F60		ASTM A694		ASME 16.47								
		40"	56"		Forged / 600# RF	A694 Gr. F70		ASTM A694		ASME 16.47								
	Blinds	1"	10"		Forged / 600# RF	ASTM A350 LF2		ASTM A350		ASME B16.5								
		12"	24"		Forged / 600# RF	ASTM A350 LF2		ASTM A350		ASME B16.5								
		28"	36"		Forged / 600# RF	A694 Gr. F60		ASTM A694		ASME 16.47								
		40"	56"		Forged / 600# RF	A694 Gr. F70		ASTM A694		ASME 16.47								