

DATE	QUESTION	ANSWER
13.9.2017	<p>1. What is the desired tender evaluation criterion in regard to the power consumption figures?</p> <p>a) Compressor power, measured where? or b) Electrical power value measured @ Trafo input or Main Switch terminals?</p>	<p>1. It is foreseen that the measurement of electrical power value from EMCS shall be in the MV-Switchgear.</p> <p>Please see also chapter 5.4 of MS-Specification: "For all current and voltage measurements, disconnect terminals and connection sockets for connection of external measurement devices shall be installed".</p>